

*There are no amendments for the 2021/22 season*

## NATIONAL GROUND GRADING - CATEGORY A

### (Appropriate to NLS Step 1 - National League)

NB The suitability of all installations shall be at the sole discretion of the FA Ground Grading Technical Panel

#### **1. GROUND**

The ground must give an overall appearance and impression of being a football ground suitable for the highest Division of The National League System

The ground must have the potential of being upgraded to meet the criteria for membership of the EFL.

It must be possible for spectators to view the match, either standing or seated, for the full length of at least three sides of the playing area, provided that the capacity requirements detailed under 1.3 are met. Where one side is designated as spectator free, measures must be in place to ensure there is no unauthorised access.

If there are any extraneous objects, or buildings within the boundary of the ground or the ground has an irregular configuration of seating, standing and covered areas that do not conform to the recognised standard design of a football stadium, the club may not be awarded a category "A" Grading.

The location of the ground, in so far as its relation to the conurbation whose name the club bears, or is traditionally associated with, must meet with the approval of The Football Association and the Board of Directors of the National League.

The club must disclose plans and details of any proposed future move to a new stadium or of any significant alteration to the existing ground to both The Football Association and the Board of Directors of the National League.

#### **1.1 Security of Tenure**

The club must demonstrate security of tenure as required by The Football Association and the league of which it is a member. (Standardised Rule 2.3.2)

NB To be eligible for promotion to the EFL a club must be able to demonstrate security of tenure for a minimum unexpired term of 10 full Seasons, from the time of a club's entry into the EFL.

In addition, the club must disclose:

- (a) Whether any Director or material shareholder of the club or any connected person or company has a financial interest in the ground.
- (b) Whether the club's occupation of the ground is subject to any third party option.
- (c) If any applicable planning consent are subject to restrictions, and

- (d) Whether the ground is charged by way of security.
- (e) Any break clauses in the lease exercisable either by landlord or tenant.

The club must provide copies of any documents so disclosed and The Football Association and the National League reserve the right to call for further information.

## **1.2 Ground Share**

Ground sharing is permitted in accordance with the provisions of individual league rules and the Regulations for the Establishment and Operation of the National League System.

**NB:** In the EFL, Ground sharing will only be approved at the discretion of the Board. The Board will ordinarily withhold approval in circumstances where the proposed ground share arrangement would result in the Club sharing occupation of the playing surface with more than one other individual team from another sport (by way of example, a Club sharing with one Rugby League team will be acceptable, but a Club seeking to share with a Rugby Union team and a Rugby League team, or two Rugby Union teams, will not).

To be eligible to ground share in the EFL a club must have a pitch of a hybrid (Desso or equivalent) construction and any ground share agreement must give the club priority of its first team matches over the activities of any other party to the agreement and the ability to postpone any activities scheduled to take place on the pitch in the immediately preceding 48 hour period where there is a risk that such activity may result in the subsequent postponement or abandonment of an EFL match.

## **1.3 Capacity**

The stadium must have a minimum capacity of 4,000 spectators, including the seated spectators, as certified by the local authority or calculated by a competent person, in accordance with the "Guide to Safety at Sports Grounds", (Green Guide) current edition at the time of inspection, with the potential to achieve a capacity of 5,000 in the future. The Football Association and the National League reserve the right to appoint a suitably qualified person to review and, if found necessary, amend the capacity figure.

The club must have the ability to segregate home and visiting supporters. Any segregated area must have exclusive entrances, exits, ladies and gents toilet facilities and catering facilities. The latter may be of the mobile type.

NOTE: All National League fixtures come under the Football Spectators Act 1989 (Football banning order legislation), and the Football (Offences) Act 1991.

## **1.4 Boundary of the Ground**

The ground must be enclosed with an external boundary wall of sound construction, secure on all sides of the ground and sufficient to deter would be climbers. The boundary must be of sound construction of pre cast concrete, brick, breezeblock or metal cladding with steel or concrete posts and be of a minimum height of 1.83 metres as measured from outside the ground.

Lapped timber, latch panel wood fences and wire mesh fences with wooden posts may be acceptable. Hedges, shrubs and/or trees will not normally be accepted

Where any side of the ground is bounded by private land/property, the fixed boundary of that private land / property may be acceptable as the boundary of the ground

Where a side or an end of the ground is designated spectator free because of an adjoining sports field or amenity there must be a fence along the entire length or width of the ground to separate the two facilities. The fence, which may be demountable, must be a minimum height of 1.83 metres and it must not be possible to view the match from outside.

### **1.5 Clubhouse**

There must be a clubhouse facility either on or adjacent to the ground and that should open on match days to provide refreshments to spectators and visiting Players, Officials and Match Officials, unless provided for elsewhere in the Ground.

### **1.6 Parking Facilities**

Parking facilities must be provided for directors, with a minimum number of 4 places for visiting directors.

There must be safe parking arrangements for the visiting team's coach.

Unmarked parking facilities must also be provided for the match officials.

Car parking within the boundary of the ground on match days may not be acceptable.

### **1.7 Pitch Perimeter Barrier**

Subject to the provisions detailed below, there must be a permanent fixed barrier ideally 1.1 m high as measured from the spectator side, of sound construction (eg concrete and steel) and free from all sharp edges, surrounding the pitch on all sides that may be occupied by spectators. Existing barriers/rails not at 1.1m high may be acceptable, provided they meet the requirements set out in 1.7 of the Appendix. Any barriers installed at new grounds should be purposely designed, with integrated infill panels as required and be made from UPVC or coated metal.

The barrier, if other than solid wall type of construction, must be infilled so that the ball cannot pass through or under it. Plastic multi-purpose hi-vis fencing is not considered suitable for infill.

Ideally there should be 2.75 metres, but no less than 2.25 metres between the touchline, goal line and the pitch perimeter barrier. In the case of new stadium, the minimum must be 3 metres.

Immediately in front of seated accommodation the boundary of the playing area may be indicated by means other than a permanent fixed barrier, provided that the Club is able to provide assurances that no spectator will be allowed to stand in this area to watch the match.

Where there is a walkway in front of a standing terrace that itself is fronted by a crush barrier that has been subject to an annual risk assessment and, if necessary, tested, an alternative to a fixed barrier (e.g. "A" Frames) may be used, provided no spectators are allowed to stand in this area to watch the match. The Club must implement a safety management system to ensure this and also to protect the integrity of the playing area.

NB where A-frames are utilised instead of a fixed barrier, they must be continuous.

(See also Appendix)

## 1.8 Pitch Standards

The playing surface must be grass, unless otherwise authorised by the Competition's Board of Directors, and must be of the highest possible standard. It must be level and free from surface depressions and excessive undulations.

The maximum slope allowable shall not exceed an even gradient of vertical to horizontal 1: 41 in any direction. NB When a new pitch is being developed or significant improvements made to a pitch, the gradient of 1:41 would not be acceptable and the pitch must be constructed with reference to the FA Performance Quality Standard.

The playing surface must be maintained to a standard acceptable to the competition in which the club is playing or seeks to play.

### **3G football turf**

3G football turf may only be used provided conditions (i) to (vi) below have been met (the "Performance Standard"):

- (i) The pitch must be surfaced with 3G football turf that has laboratory type approval according to the FIFA Quality Concept for Football Turf (2012 & 2015 editions) – FIFA Recommended Two Star/Quality Pro performance.
- (ii) The 3G football turf pitch must be listed on The Association's register of 3G football turf pitches by no later than 31 May and tested annually at the Club's expense
- (iii) Where a 3G football turf pitch is not yet listed on The Association's register (for example if it is a newly installed pitch), a Club must obtain a Laboratory Performance Test Report and submit it to The Association by no later than 31 July.
- (iv) The Association reserves the right to instruct a Club to have its pitch tested at any time in order to ensure that it meets the Performance Standard. All such tests shall be at the Club's expense.
- (v) The 3G football turf, including run-offs, shall be one continuous playing surface and shall be green in colour at least one metre from the outer edge of the touchline and goal line. All line markings shall be in accordance with the Laws of Association Football.
- (vi) From season 2016/17 only Clubs with FIFA recommended Two star/FIFA Quality Pro pitches will be eligible to take part in matches under the auspices of National League (ie NLS Steps 1 and 2) SAVE THAT a Club which has a ground with the recommended FIFA 1 star/FIFA Quality or IATS/IMS certificate can be promoted to Step 2 of the National League System, provided that it undertakes, upon renewal of the pitch, to install a pitch that meets the FIFA Quality Pro standard and is certified.

A Club wishing to be promoted to Step 2 of the National League System with a 3G football turf pitch must test the pitch by 31 March to the FIFA Quality Pro performance criteria to ensure it meets the standard required. Any remedial work to meet the FIFA Quality Pro standard must be completed by 31 May.

NB **No** EFL Matches shall be played on an Artificial Surface. Where an Applicant Club (as defined in EFL Regulation 7.1) has a pitch constructed from an Artificial Surface, that Club must ensure that the Artificial Surface is removed and will be replaced by a grass pitch prior to the date on which the Board considers the application for the transfer of membership from the relegated Club to the Applicant Club (as determined in accordance with the Articles of Association).

### **1.9 Playing Area**

The playing area must be a minimum of 100 metres x 64 metres and must conform to the requirements of the Laws of the Game.

Goalposts and goal net supports must be of professional manufacture and conform to the relevant safety requirements and the requirements of the Laws of the Game.

The Club must be responsible for the up keep of the playing area. The details of any other person/company/organisation responsible for the up keep of the playing area, on behalf of the club, must be disclosed to The Football Association and the National League Board.

(See also Appendix)

### **1.10 Technical Area**

Two covered trainers' boxes clearly marked "Home" and "Away or Visitors" must be provided unless adequate provision is made in a seated stand. They must be on the same side of the pitch ideally either side of the halfway line, ideally both equidistant from it and ideally a minimum of 3 metres apart and provide an unobstructed view of the playing area.

NB When new boxes are being constructed or installed, they must be on each side of the half way line, equidistant from it and a minimum of 3 metres apart.

Each of the seating areas must be able to accommodate a minimum of 11 adults on fixed seats or benches. Where bench seating is provided, a minimum of 0.5m must be allowed for each person. (i.e. 11 persons require a minimum of 5.5 metres)

Portable trainers' boxes are permitted but must be securely fixed while in use.

A technical area must be marked out, in accordance with the guidance contained in the 'Laws of the Game' booklet.

### **1.11 Safe Walkway**

There must be a safe, unimpeded passage for players and match officials between the dressing rooms and the pitch.

The use of protection designed products such as retractable tunnels or permanent structures to separate players and spectators is recommended.

The design of the safe walkway will inevitably differ from ground to ground and it will rarely guarantee the safe passage of players and match officials unless supplemented by stewards. A club should implement procedures appropriate to the particular structure and be ready to respond to on the field situations which might affect spectator behaviour.

### **1.12 Floodlighting**

Floodlights must be provided to an average lux reading of at least 250. No single reading can be less than 100 lux nor less than one quarter of the highest reading so as to ensure an even spread of light.

Readings shall be on a grid of 88 markings (8 across and 11 down) evenly spaced with the outside readings taken 2.5 metres inside from the touchline. The average of all the readings is taken to be the average illumination level in lux of the floodlighting installation.

The lux values must be tested every two years in accordance with current guidelines by an approved independent contractor. Floodlights must be retested after any significant alterations. Existing certification will be accepted provided that the test was carried out within the last two years unless work has been carried out at the ground which may have affected the previous readings.

It is also recommended that at the same time as testing the lights clubs also test the electrical supply within the ground to ensure that the system complies with current electrical standards and request a visual inspection of the columns for signs of corrosion, fatigue and overloading.

When applying for a higher grading, the certificate should have been issued no more than six months prior to application.

An example of an “approved” contractor is one which is in possession of the NICEIC (National Inspection Council for Electrical Installation Contracting) Approved Contractors Award or ISO 9000/BS 5750 (International Standards/British Standards) or is a member of the Electrical Contractors' Association. Alternatively, it can be a contractor deemed acceptable by the league.

The Contractor must, when detailing the lux values, give confirmation in writing of the date when the illumination test equipment was last calibrated.

Further information: -

The EFL average lux value for League Two is 500 lux with a minimum at any one point of 300 Lux. A new club entering League Two must comply with the minimum floodlighting requirements by 1<sup>st</sup> July prior to its first season as a Member Club.

### **1.13 Public Address System**

A public address system must be provided which is clearly audible in all areas of the ground which can be occupied by spectators.

### **1.14 Entrances**

There must be at least 8 spectator entrances to control the ingress of spectators. These must be controlled by fully operational turnstiles of the revolving type and must be suitably housed and lit. Adequate protection and security for the turnstile operator must be incorporated. These entrances should be placed in appropriate positions around the boundary of the ground and take into account the requirements of segregation.

Electronic turnstiles with bar code readers are also acceptable but an emergency procedure must be in place in the event of a power failure.

Adequate protection and security must be incorporated for the turnstile operator or, where tickets are sold from a box office, the cashier.

It must be possible to gain access to the spectator viewing areas from the turnstiles via a bound surface minimum width of 0.9 metre.

### **1.15 Exits**

All exits must be clearly signed, ideally with “running man” signs, and are to be kept clear and free from obstructions. (For further information, reference should be made to the Guide to Safety at Sports Grounds.)

There must be access via a bound surface to all exits from the nearest spectator viewing areas.

### **1.16 Lighting**

There must be an emergency lighting system for all spectator areas and concourses as required by the local Safety Authority or approved by a competent person.

(See also Appendix)

### **1.17 TV Gantry/Camera platform**

A permanent TV gantry or camera platform that meets the following minimum criteria:

Clubs are to provide a suitable position in the stadium from which to film single camera footage of matches. This should be exactly on the halfway line, facing away from the sun and protected from the weather, at least 4 metres above pitch level, and have a nearby 13A power socket. The ideal angle is 12-14 degrees to the centre line and 22-24 degrees from the near-side. If there is no existing gantry, a scaffold should be built, insured and properly maintained to Health & Safety Executive standards.

Please note: The EFL issues its own guidelines for TV coverage facilities.

### **1.18 Adjoining Pitches**

Where deemed that they are likely to interfere with the playing of a match ball games must not be played on adjoining pitches whilst a match is in progress.

### **1.19 Emergency Access**

Access must be provided for emergency services maintained free from obstruction.

## **2. SPECTATOR FACILITIES**

### **2.1 Spectator Accommodation**

Covered accommodation, which should preferably be on at least 2 sides of the ground, must be of sound construction of timber/steel/brick/concrete or any combination of these materials. Existing timber stands are only acceptable subject to a fire risk assessment conducted by a competent person.

The minimum covered seated accommodation must be 500. These may be located in two stands of which at least 250 shall be seats located in one stand, with no stand having less than 100 seats. These seats may be inclusive of Directors/Committee and press seating.

A minimum of FOUR rows is required to the dimensions recommended in the Green Guide. In order to meet the sight line requirements it is recommended that the first line of seating is located above pitch level. There must be an unobstructed view from the lowest level of the seated area.

All seating should afford a good and full view of the pitch and be clean, functional and in good condition. Seats should ideally be tip-up type with back rests. Alternatively, other than the Directors Box, the seats can be of the plastic moulded type complete with backrests or other types of seats provided that they have backrests.

Existing bench seating may be permitted provided that it is in good repair and that individual spaces (min 500mm) are clearly marked but will NOT be included in any calculation for the required minimum covered seating accommodation of 500.

Temporary structures will not be accepted.

The Directors Box must be clearly defined and should enjoy a prime position in the main stand. There must be individual seats and the Home and Away areas clearly marked.

Home - minimum number of seats 24  
Away - minimum number of seats 16

Standing spectators are not allowed in or near a seated spectators' stand where they can obstruct the views.

Areas where no spectators are permitted to stand must be clearly marked with hatched yellow markings. Alternatively, appropriate signage may be acceptable.

Clubs must be able to demonstrate that visiting supporters can be segregated when necessary.

NOTE: Clubs may retain membership of the National League Step 1 Division provided they have achieved a Category "A" Grading by 31<sup>st</sup> March in the year following promotion.

To qualify for promotion to EFL by winning the Championship and for the club to participate in the promotion play off matches, the ground must achieve a Category "A" Grading together with 500 seats under cover by 31<sup>st</sup> March in each season

## **2.2 Press Seating**

A minimum of 12 seats must be provided with lighting and writing facilities for the use by the press and other media. The press seating must have a clear view of the field of play.

## **2.3 Terracing**

All terracing must be in sound condition and must comply with the requirements of the Green Guide. Terracing that is crumbling, has grass/weeds growing through it or has broken or loose concrete will not be accepted.



Any level surfaces within the ground must be hard standing. i.e. tarmac, concrete, concrete paving or other approved materials. Spectator standing areas behind the goals must be terraced unless the overall ground capacity is achieved with the exclusion of one or both of these areas. The number of terrace steps to be commensurate in achieving the overall ground capacity.

Grass banking may not be acceptable within the ground. Grass banking within the ground must not be accessible for spectators to view the match. The installation of permanent barriers of a suitable height but not less than 1.1 metres will be required. The use of demountable or semi-permanent type fencing is not acceptable.

All visible grassed areas must be well maintained.

## **2.4 Toilets**

There must be adequate toilet facilities for men and women in each area of the ground commensurate with the capacity of that area in accordance with the Green Guide.

A minimum of two units of toilet facilities must be provided located in two separate areas within the ground, excluding those located in the clubhouse, or accessible only from within the main stand. Each unit to contain the minimum of:-

Male: 4 - urinals or equivalent and two WC's

Female: 2 - WCs

In addition, there must be hand wash basins with running water, warm air hand driers and/or paper towel dispenser and waste bins in each toilet area. Whilst replaceable linen roller towels in a cabinet are acceptable, individual hand towels are not permitted

All toilet areas must be in working order, with a roof and operational lighting, supplied with toilet paper and maintained to the highest level of cleanliness.

These facilities may be of a temporary or mobile kind but must be connected to the mains supply (ie water and power) and main drainage or an acceptable alternative drainage system. They must be fully accessible with permanent access.

Individual toilet units often known as 'portaloos' are permissible on a temporary basis but may not be included in the minimum toilet requirements.

Clubs are recommended to refer to the guidelines in respect of new toilet installations as set out in the Football Stadia Advisory Design Council publication.

The location of all toilet facilities must be indicated with appropriate signage

## **2.5 Refreshment Facilities**

### **2.5.1 Directors/Committee/Guests**

A separate Directors room, ideally near to or adjacent to the Directors seating, must be made available in which refreshments for Directors and guests can be served. The room must be able to accommodate a minimum of 24 persons with nearby toilet facilities.

### 2.5.2 Ground Refreshment Facilities

Refreshment facilities must be available to spectators in each separate area of the ground. These may be of the mobile type.

### 2.6 Disabled Facilities

(See Appendix)

## 3. DRESSING ROOM FACILITIES

### 3.1 Players

Separate dressing rooms must be provided for the teams within the enclosed area of the ground. The dressing rooms must be of sound construction of a permanent nature. The minimum size for each changing area is 18 sq. metres excluding the shower and toilets areas. Clubs should be aware of the need to increase to a minimum of 30 square metres for membership of the EFL by 30<sup>th</sup> April following promotion as into League Two.

Each dressing room must have:-

- (a) A shower area comprising at least 4 shower heads  
Note: 6 shower heads are required to meet the EFL criteria.
- (b) At least one hand wash basin located outside the shower area.  
Note: 2 hand wash basins are required to meet the EFL criteria.

All of the above must have hot and cold running water

- (c) Two urinals
- (d) One WC in a cubicle  
Note: 2 WC's are required to meet the EFL criteria.

There must be a treatment table which is clean and in good condition in each dressing room.

### 3.2 Match Officials

The size of the match officials' dressing room must be a minimum of 6 square metres excluding the toilet and shower areas. Clubs should be aware of the need to increase to a minimum of 10 square metres for membership of the EFL by 30<sup>th</sup> April following promotion into League Two.

The match officials' dressing room must have:-

At least one shower, one wash basin (both with hot and cold running water)

(NB On promotion to EFL an additional shower will be required.)

At least one WC in a cubicle

Provision should be made for separate dressing rooms for male and female match officials.

Where new dressing rooms are being constructed or existing ones are being re-designed, separate purpose built facilities for male and female match officials must be provided.

There must be an audible electronic warning device (bell or buzzer) in working order located in the match officials' dressing room linked to both players' dressing rooms.

**NOTE: ALL DRESSING ROOM AREAS MUST BE MAINTAINED TO A HIGH STANDARD OF CLEANLINESS AND TO BE HEATED, WELL VENTILATED AND SECURE ON MATCH DAYS.**

#### **4. MEDICAL**

There must be a suitably equipped medical treatment room for players located in the vicinity of the players' dressing rooms. Access to this room must not be via the home or away dressing rooms.

There must be a suitably equipped and designated First Aid Room for spectators within the boundary of the ground fitted out with services in accordance with Health & Safety requirements. The designated room must contain a bed or comfortable seating, with cold and, ideally, hot water, together with paper towels. Reusable individual towels are not permitted.

The first aid room and the location of the room must be suitably sign posted.

At least one stretcher for the removal of injured players from the field of play must be provided.

(See also Appendix)

#### **5. APPLICATION FOR MEMBERSHIP OF THE EFL**

##### **FORMAL APPLICATION**

It is the responsibility of each Club seeking promotion from Step 1 to the EFL to source the relevant information, issued from time to time by the EFL, in order to enter an 'Application for Membership'.

All applications for membership must be made via an online survey (link provided by the EFL).

## APPENDIX

### **1. GROUND**

#### **1.7 Pitch Perimeter Barrier**

It is important to distinguish between a pitch perimeter barrier/rail which exists to separate spectators from the playing area and a crush barrier which has been constructed and tested in accordance with the requirements of the Green Guide. Where the structure cannot be designated as a crush barrier, e.g. its height exceeds 1.1m, the maximum depth of standing behind it is limited to 1.5metres and this must be borne in mind in any capacity calculations.

It is recognised that the above may not be an issue for normal attendances but, when a larger crowd is anticipated, the Club should be mindful of the associated management issues and, if necessary, take professional advice.

Whatever system is employed, a club should be mindful of its responsibility to ensure spectator safety and minimise the possibility of unauthorised incursions on the playing area.

#### **1.9 Playing Area**

Reference should be made to the Goalpost Safety information published by The Football Association and, in particular, it should be noted that the use of metal cup hooks is prohibited.

#### **1.16 Lighting**

Clubs are reminded that they have a responsibility to ensure the safety of spectators entering, leaving and moving about the ground and, if a ground is used in non-daylight hours, adequate artificial lighting should be provided. Further, consideration must be given by a club to its procedures in the event of a power failure.

### **2. SPECTATOR FACILITIES**

#### **2.6 Disabled Facilities**

A club must take account of the needs of disabled spectators and be mindful of its obligations under the provisions of the Disability Discrimination Act 1995. Reference may be made to the publications / data sheets issued by both The Football Association and the Football Foundation.

No specific requirement is currently included in the grading criteria but The Football Association strongly recommends that access is provided to both a covered viewing area and toilet and refreshment facilities.

When considering the installation of viewing facilities for disabled spectators, the EFL are asking clubs to install disabled viewing facilities in segregated home and away areas of the ground.

### **4. MEDICAL**

There must be a nominated and suitably qualified person in attendance to assist with spectator problems unless the St John Ambulance Brigade, Red Cross Society or other capable agency are in

attendance. The requirements of the Guide to Safety at Sports Grounds are for one first aider per 1000 anticipated spectators, with a minimum of two.

If a crowd of less than 2000 is anticipated, known and practiced arrangements should be in place to summon either a doctor or NHS ambulance alternative. For crowds of over 2000, an experienced crowd doctor should be in attendance.

NB The above in no way purports to be a comprehensive list of Health and Safety issues which it is the responsibility of a club to address. Clubs are recommended to arrange regular safety audits conducted by persons with the appropriate expertise.